




IS 1001



1 INSTALLATION SPACING / ESPACEMENT D'INSTALLATION / ESPACIADO DE INSTALACIÓN / INSTALLATIONSABSTAND




RISK OF FIRE: Required clearance from structural members and building elements

SCB: 50mm HCB: 50mm MIC: 0mm SCI: 0mm


HCB: Height clearance to building element
MIC: Minimum insulation clearance
SCI: Side clearance to insulation
SCB: Side clearance to building element

2 HOW TO INSTALL THE BEZEL / INSTALLATION DE LA COLLERETTE / INSTALACIÓN DEL EMBELLECEDOR / MONTAGE DER BLENDE

Disassemble



Assemble



3 DOWNLIGHT WITH TERMINAL BLOCK / SPOT ENCASTRÉ AVEC BORNIER DE RACCORDEMENT / DOWNLIGHT CON REGLETA DE CONEXIONES / DOWNLIGHT MIT ANSCHLUSSKLEMME

